

Frequency of Testing Fire Systems in South Australia

1990 to 2014	Weekly	Monthly	Quarterly	6 Monthly	Annually	3 Yearly	6 Yearly
Fire Extinguishers				✓	✓	✓	✓
Fire Hose Reels				✓	✓		
Fire Blankets					✓		
Fire Alarm and Detection Systems		✓			✓		
Emergency Warning and Warden Intercommunication Systems		✓			✓		
Fire Sprinkler Systems	✓		✓		✓	✓	
Fire Hydrants and Boosters		✓			✓	✓	✓
Fire Pumps and Tanks	✓			✓	✓		
Fire Compartmentation					✓		
Fire Doors		✓			✓		
Solid Core Doors					✓		
Smoke Doors		✓			✓		
Exit and Emergency Lighting		✓		✓	✓		
Means of Egress			✓				
Signage Related to Emergencies					✓		

Source: Ministers Specification SA76:2000

Frequency of Testing Fire Systems in South Australia

March 2015 onwards	Monthly	Quarterly	6 Monthly	Annually	5 Yearly
Fire Extinguishers			✓	✓	✓
Fire Hose Reels			✓	✓	
Fire Blankets				✓	
Fire Alarm and Detection Systems	✓			✓	
Emergency Warning and Warden Intercommunication Systems	✓			✓	
Fire Sprinkler Systems	✓	✓		✓	✓
Fire Hydrants and Boosters			✓	✓	✓
Fire Pumps and Tanks	✓		✓	✓	
Fire Compartmentation				✓	
Fire Doors			✓	✓	
Fire Doors (Sliding)		✓	✓	✓	
Solid Core Doors				✓	
Smoke Doors	✓			✓	
Exit and Emergency Lighting	✓		✓	✓	
Means of Egress		✓			
Signage Related to Emergencies				✓	

Source: Ministers Specification SA76:2015